



1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
2. MINIMUM CONCRETE COVER TO REINFORCEMENT IS AS SHOWN THE DRAWING.
3. REINFORCEMENT TO BE DEFORMED ROUND STEEL BARS TYPE 2 GRADE 500 COMPLYING WITH REQUIREMENTS OF BS 4449 AND CUT AND BENT IN ACCORDANCE WITH BS 8666.
4. REINFORCEMENT SHOWN IS INDICATIVE. DESIGN DRAWINGS SHALL BE PREPARED AND DESIGNERS SHALL PROVIDE THE BAR DIAMETERS REQUIRED BY THE DESIGN.

1	23/10/2013	REVISED LOGO AND DWG NUMBER	I. FLYNN
Rev.	Date	Revision Details	Appd.


هيئة الأشغال العامة
Public Works Authority
 P.O.Box 22188
 Tel.: (0974) 44950000
 Fax.: (0974) 44950999
www.ashghal.gov.qa

PA
PROJECTS AFFAIRS

QCS Section: 5 (CONCRETE)
PART 1 (GENERAL)

Drawing Title:

Q-GIRDER REINFORCEMENT

Approved: I. FLYNN	Sheet No: 1 OF 1
Date: OCTOBER 2013	Scale: AS SHOWN @ A1
Drawing Number: SD 5-1-102	Revision: 1