



- 1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
- 2. MINIMUM CONCRETE COVER TO REINFORCEMENT SHALL BE IN ACCORDANCE WITH EXW DESIGN CRITERIA.
- 3. REINFORCEMENT TO BE DEFORMED ROUND STEEL BARS TYPE 2 GRADE 500 COMPLYING WITH REQUIREMENTS OF BS 4449 AND CUT AND BENT IN ACCORDANCE WITH BS 8666.
- 4. REINFORCEMENT SHOWN IS INDICATIVE. DESIGN DRAWINGS SHALL BE PREPARED AND DESIGNERS SHALL PROVIDE THE BAR DIAMETERS REQUIRED BY THE DESIGN.

1	23/10/2013	REVISED LOGO AND DWG NUMBER		I. FLYNN		
Rev.	Date	Revision Details		Appd.		
ميئة الأشغال العامية Public Works Authority						
P.O.Box 22188 Tel. : (0974) 44950000					IGHA L	
Fax. : (C www.as	1974) 44950999 hghal.gov.qa			ـق الأفضــل Qatar Deser	قطرتستد ves The Best	
PA						
PROJECTS AFFAIRS						
^{QCS Section:} 5 (CONCRETE) PART 1 (GENERAL)						
Drawin	ig Title:	TV D		19		
TY - BEAMS CONTINUITY AT						
INTERMEDIATE SUPPORT						
	SHEET 2					
		SHE				
Approve	^{d:} I. FLYNN	SHE	Sheet No:	1 OF 1		
Approve Date:	OCTOBER			1 OF 1 AS SHOW		
Approve Date:	OCTOBER		Sheet No: Scale:		N @ A1 Revision: 1	