



OPTION 2 TYPICAL CROSS SECTION THROUGH DECK ADJACENT TO SUPPORTS

## NOTES:

- 1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
- 2. MINIMUM CONCRETE COVER TO REINFORCEMENT SHALL BE IN ACCORDANCE WITH EXW DESIGN CRITERIA.
- 3. REINFORCEMENT TO BE DEFORMED ROUND STEEL BARS TYPE 2 GRADE 500 COMPLYING WITH REQUIREMENTS OF BS 4449 AND CUT AND BENT IN ACCORDANCE WITH BS 8666.
- 4. REINFORCEMENT SHOWN IS INDICATIVE. DESIGN DRAWINGS SHALL BE PREPARED AND DESIGNERS SHALL PROVIDE THE BAR DIAMETERS REQUIRED BY THE DESIGN.

1	23/10/2013	REVISED LOGO AND DWG NUMBER	I. FLYNN
Rev.	Date	Revision Details	Appd.
يامـــة Public	الأشغــال الع Works Autl	میئے میئے nority	

## فيتـــه الاسعــال العامـــه Public Works Authority

P.O.Box 22188 Tel.: (0974) 44950000 Fax.: (0974) 44950999 www.ashghal.gov.qa

فطر تستحق الأفضل Qatar Deserves The Besi

## PA PROJECTS AFFAIRS

5 (CONCRETE) PART 1 (GENERÁL)

TY - BEAMS CONTINUITY DETAIL AT INTEGRAL ABUTMENT

Approved: I. FLYNN	Sheet No: 1 OF 1	
Date: OCTOBER 2013	Scale: AS SHOWN @ A1	
Drawing Number:	Revision:	
00.54.44	-   4	

SD 5-1-115