




STEP 1
EXCAVATE PIT FOR GULLY
(AFTER ROADWAY SUB-GRADE/FORMATION LEVEL)
PREPARE BASE




STEP 2
INSTALL GULLY POT AND 150 mm CONCRETE SURROUND




STEP 3
PROVIDE BLOCKOUT AT PIPE OPENING AND BACKFILL WITH FLOWABLE FILL




STEP 4
EXCAVATE PIPE TRENCH AND INSTALL
PIPE, CONCRETE SURROUND AND
BACKFILL




STEP 5
INSTALL TEMPORARY STEEL PLATE AND CONSTRUCT SUB BASE
CONSTRUCT KERBS AND FOUNDATIONS. LOWER BOTTOM OF
FOUNDATION TO TOP OF GULLY POT IN AREA OF GULLY. CONSTRUCT
EDGE OF FOUNDATION FLUSH WITH FACE OF KERB IN AREA OF GULLY




STEP 6
LAY BASE COURSE AND INTERMEDIATE COURSE




STEP 7
SAW CUT AND REMOVE BASE COURSE AND SUB BASE
REMOVE STEEL PLATE, TRIM EXCAVATION




STEP 8
INSTALL GULLY COVER SLAB AND MAKE-UP BLOCKS




STEP 9
INSTALL GRATE FRAME, PROVIDE CONCRETE SURROUND



STEP 10
INSTALL TEMPORARY STEEL PLATE IN GRATE OPENING AND LAY
WEARING COURSE



STEP 11
REMOVE TEMPORARY STEEL PLATE INSTALL GULLY BASKET AND
GRATE



PLAN

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
2. TOP ENTRY GULLY X VALUE BASED ON 2 MAKE-UP BLOCKS, 1 GULLY COVER SLAB AND 100mm HEIGHT OF GRATE FRAME.
3. GULLY COVER SLAB TO BE 650x750x100 WITH 300 DIAMETER OPENING IN CENTER FOR GULLY BASKET SUPPORT.
4. CONTRACTOR TO POSITION GULLY POT, COVER SLAB, BLOCKS AND GRATE TO FACILITATE INSTALLATION AND REMOVAL OF GULLY BASKET.
5. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH STANDARD DRAWING No. SD 6-17-102.

LEGEND:

FRL	FINISHED ROAD LEVEL
GRP	GLASS REINFORCED PLASTIC

1	APR 19	ISSUED FOR USE	
0	01 MAR 19	ISSUED FOR USE	
Rev.	Date	Revision Details	Appd.
هيئة الأشغال العامة Public Works Authority			
P.O.Box: 22188 Tel.: 00974 44950000 Fax: 00974 44950999 PA PROJECTS AFFAIRS QCS Section:			
Section 6 - Road Works Part 17 - Road Drainage			
Drawing Title: TOP INLET GULLY ADJACENT TO KERB INSTALLATION SEQUENCE			
Approved:		Sheet No: 1 OF 1	
Date: APRIL 2019		Scale: NTS	
Drawing Number: SD 6-17-112			Revision: 1