



TYPICAL PIPE SUPPORT IN MANHOLE / CHAMBER
SCALE 1:5

- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
 2. ALL MATERIALS AND WORKMANSHIP SHALL BE IN ACCORDANCE WITH THE CURRENT Q.C.S. UNLESS OTHERWISE AGREED WITH THE ENGINEER.
 3. STAINLESS STEEL STRAPS GRADE 316 UNLESS NOTED OTHERWISE.
 4. ALL STAINLESS STEEL WELDS PASSIVATED.
 5. ANCHOR BOLTS STAINLESS STEEL UNLESS NOTED OTHERWISE.
 6. PLACE PIPE SUPPORT WITHIN 300mm OF ALL PIPE JOINTS WITH 2000mm MAX SPACING.
 7. FOR D.I. PIPES, PROVIDE NEOPRENE OR POLYTHENE STRIP BETWEEN PIPE AND STAINLESS STEEL STRAPS TO INSULATE DISSIMILAR MATERIALS.

3	APR 19	ISSUED FOR USE	
2	01 MAR 19	REVALIDATED ISSUE	
1	30JUL 15	ISSUED FOR USE	
0	15SEP13	ISSUED FOR USE	
Rev.	Date	Revision Details	Appd.

هيئة الأشغال العامة
Public Works Authority

P.O. Box: 22188
Tel.: 00974 44950000
Fax: 00974 44950999
PA
PROJECTS AFFAIRS

قطر تستحق الأفضل
Qatar Deserves The Best
www.ashghal.gov.qa

QCS Section:
Section 8 - Drainage Works
Part 6 - Miscellaneous Metal Works

Drawing Title:

**PIPE SUPPORT
DETAILS**

Approved:	Sheet No:	1 OF 1
Date:	APRIL 2019	Scale: 1:5 on A1
Drawing Number:	SD 8-6-102	Revision: 3