هيئـــة الأشغــال العـامــة Public Works Authority



## **PRE-OUALIFICATION CIRCULAR NO. 01**

To

: All Applicants

**Total Pages** 

: 2

Date

: 17 December 2015

PROJECT

: PRE-QUALIFICATION FOR APPROVED DRAINAGE CCTV

SURVEY CONTRACTORS (EXPRESSION OF INTEREST)

SUBJECT

ANSWER TO PQ QUERIES

Applicants are hereby informed of the following amendments, clarification and elaboration to the PQ documentation for the above project:

No.	PQ QUERY	ANSWER
1.	I have just received an invitation to pre-qualify for CCTV survey works. We submitted a pre-qualify submission for the same CCTV survey works in April/May 2015 to a Mr. Steve Bird. I have attached these pre-qualifying documents for your reference. Please can you let me know if we are to prepare a new submission or you will except the one submitted in April/May 2015	You should submit a new proposal in line with the published RFP.
2.	Please refer to the web-page of the "Prequalification", namely "Camera Specifications" which is the fifth paragraph under "Scope of Services". It describes the required camera to be pan and tilt for sizes less than 450mm, and pan, zoom and tilt for larger sizes.  On the other hand, please refer to: Prequalification Documents - Part 2 Work Requirements - page 74. It only specifies the "light ring survey" (a.k.a.	Light Rings are to be used for flexible pipes and all other types of pipe CCTV system is to be used.

No.	PQ QUERY	ANSWER
	laser profiler) Please confirm whether both systems are required, i.e. the PTZ plus the "light ring"	
3.		The contractor should use the Scoring Criteria of IBAK (European German Standard).

All other conditions remain unchanged.

This circular shall be included in the submitted PQ document and will be deemed to form part of and allowed for in your PQ submission.

Please acknowledge receipt of this Circular via returned email to contracts@ashghal.gov.qa

Regards,

on behalf of Ghanem Rashid Al-Mansoori

Manager of Contract Department